



Telephone:0484-2623576
email:-qcldaluva@gmail.co

KERALA WATER AUTHORITY
QUALITY CONTROL DISTRICT LAB,ALUVA -683101
WATER TEST-BACTERIOLOGY REPORT

Report No: KWA/QCDL-A/S/15719/22-23


Report Issue Date: 12.03.2024

Customer Name &Address		Date of Receipt of Payment	28.02.24	
Arch Bishop Attipetty Public School		Date of Sample received	06.03.24	
		Sample given by	Customer	
		Sample Code	ALY/S/15719/3/24	
		Sample Name	Drinking Water	
		Sample Condition	Good	
		Source of Sample	Submitted By the Party	
		Sample Quantity	200ml	
				Test performing dates :
Sl. No.	Parameter	Acceptable Limit as per IS 10500-2012	Test Method	Result
1	Total Coliform	Shall not be Detected/100ml	IS15185-2016	Absent
2	E-Coli	Shall not be Detected/100ml	IS15185-2016	Absent

NB:-1) The result stated above related only to the sample(s) submitted for testing by the customer .

2) The samples retain for 15 days from the end date of analysis

3) The test certificate shall not be reproduced except in full without the written approval of the Laboratory



Authorized By

[Signature]

End of Report

KWA/QCDE/ALY/01-2020		Issue Date : 04.10.2020	
Rev No: 01	Rev,Date : 02/06/2021	Page 1 of 1	